


AIR-GAP PROTECTION



MECHANICAL ASS'Y PROTECTION

#### REQUIREMENTS

1. AIR-GAP MUST BE APPROVED "AIR-GAP" SYSTEM.
2. MECHANICAL BACKFLOW PREVENTER MUST BE AN APPROVED REDUCED PRESSURE PRINCIPAL ASSEMBLY.
3. BACKFLOW ASSEMBLY MUST BE TESTED BY A CERTIFIED BACKFLOW PREVENTION DEVICE TESTER, WHO IS REGISTERED WITH THE CITY WATER DIVISION. THE TESTS SHALL BE PERFORMED ONCE A YEAR. THE TEST RESULTS MUST BE PROVIDED TO THE CITY WATER DIVISION.
4. TYPICAL EQUIPMENT: WATER TRUCKS, PEST CONTROL TRUCKS, HYDROSEEDING EQUIPMENT, PORTABLE WASHING AND STEAM CLEANING EQUIPMENT.